

Appendix D: Analog Parameters

Parameters not addressable by Analog Inputs

The five analog inputs of the Quantum III and Mentor II can direct their readings to a great many drive registers (via 7.11-7.15) but there are some exceptions. The destinations of their bi-polar data cannot be directed to:

- **Read Only Parameters**
- **Bit Parameters**
- **Parameters having a range of 0 - 255**

In addition to the following Parameters:

- **2.02 to 2.12**
- **3.15 and 3.16**
- **5.05**
- **6.21**
- **7.08 to 7.23**
- **8.12 to 8.20**
- **9.07, 9.09, 9.13, 9.15, 9.19, 9.21, 9.23, 9.25**
- **11.01 to 11.10, 11.18 to 11.20**
- **12.03, 12.07, 12.08, 12.12**
- **13.14**
- **15.60 to 15.63**